

Annexure D

BUILDING SAFETY CERTIFICATE

No. 015/BS2025

Date : 05/06/2025

It is certified that the existing building **Smt.Pushpa Siksha Prasar Samiti, Gwalior** (Name of the building or premises) at **Gram Chakjagrupura, Morar, Gwalior 474005** is having block(s)/Floor(s) as per details below:

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	Ground Floor	First Floor	Second Floor			

The building is ☒ owned /occupied by **CBS Convent Senior Secondary School, Morar, Gwalior** (name of the institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **Municipal Corporation, Gwalior** (Name of Department/Govt.) on **05/06/2025** (date of inspection) in the presence of **Laxman Singh Sengar, New Colony No.2/238, Birla Nagar, Gwalior 474004** (name and addresses of the Manager/Secretary or his representative) and the building/premises is fit for occupancy for running school with effect from **05/06/2025** for a period of **1 year** in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp and Railing Provided for Physically Handicapped Student
2. Stair case width is 1.50 mts. Rise of Steps is 0.15 mts treads is 0.30 mts
3. Ceiling height from floor measured and its is 3.45 mts.
4. Paved roads, available for the movement of fire engine around building.

Issued on **05/06/2025** at Gwalior By

*Strike out whichever is not applicable. In case of block is more than six use separate sheet for details.

Signature with Seal

Name

Designation

Name & Address of the Department/Office: **Personi Chhawan
Gwalior M.P. 474010**